



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**9229-16-1579**  
State Number  
**25682**

EQUIPMENT INSPECTED

State Number: <b>25682</b>	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: OTIS	Speed: 100
Landings: 4	Installed: 07/31/2008	Rope Size: 0
Volts: 208	Complied: 07/31/2008	Entrances: 1

OWNER

PROGRESS COMPANIES  
104 N MARKET STREET  
WASHINGTON, NC, 27889

OCCUPANT

MOSS LANDING  
235 E WATER STREET  
WASHINGTON, NC, 27889

INSPECTION INFORMATION

Inspection Date 08/17/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

2.27.7.1	Provide Phase I fire service instructions at the recall landing.
8.6.1.6.5	Provide the required fire extinguisher in the machine room.
8.6.4.13.1[i]	Properly maintain clutches, engaging vanes, retiring cams, and engaging rollers. 3rd floor roller

Items must be corrected by: 09/16/2009

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Stan With Progress Companies

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

PROGRESS COMPANIES  
104 N MARKET STREET  
WASHINGTON, NC, 27889