



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9230-48-3263
State Number
23912

EQUIPMENT INSPECTED

State Number: 23912	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 09/12/2006	Rope Size: 0
Volts: 208	Complied: 09/12/2006	Entrances: 1

OWNER

BRUNSWICK CO FARM BUREAU
4560 WHITE STREET
SHALLOTTE, NC, 28459

OCCUPANT

BURNSWICK CO FARM BUREAU
4560 WHITE STREET
SHALLOTTE, NC, 28459

INSPECTION INFORMATION

Inspection Date 08/18/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.11.2.2.2 Perform the annual no load safety test

Items must be corrected by: 09/17/2009

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: RODNEY BROWN

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BRUNSWICK CO FARM BUREAU
4560 WHITE STREET
SHALLOTTE, NC, 28459