



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9258-48-0572
State Number
23726

EQUIPMENT INSPECTED

State Number: 23726	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: TKE	Speed: 50
Landings: 4	Installed: 04/11/2006	Rope Size:
Volts: 230	Complied: 04/11/2006	Entrances: 1
OWNER	OCCUPANT	
OCEAN WALK HOA % BEC MGMT	OCEAN WALK CONDO #3	
1600 MORGANTOWN RD	105 SE 58TH STREET	
PINEHURST, NC, 28374	OAK ISLAND, NC, 28465	

INSPECTION INFORMATION

Inspection Date 09/15/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.7.1	Clean the elevator pit.
2.2.2.5	CHECK SUMP PUMP FOR OPERATION [FILLED TO TOP].

Items must be corrected by: 10/05/2009

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

OCEAN WALK HOA % BEC MGMT
1600 MORGANTOWN RD
PINEHURST, NC, 28374