



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9259-48-3085
State Number
24258

EQUIPMENT INSPECTED

State Number: 24258	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 50
Landings: 4	Installed: 11/07/2006	Rope Size: 0
Volts: 240	Complied: 11/07/2006	Entrances: 1
OWNER	OCCUPANT	
OCEANWALK HOA - C/O BEC MGMT.	OCEANWALK CONDOS #5	
1600 MORGANTOWN RD.	105 SE 58TH STREET	
PINEHURST, NC, 28374	OAK ISLAND, NC, 28465	

INSPECTION INFORMATION

Inspection Date 09/16/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

OCEANWALK HOA - C/O BEC MGMT.
1600 MORGANTOWN RD.
PINEHURST, NC, 28374