

N C Department of Labor Elevator Bureau 1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in any correspondence relating to your equipment www.nclabor.com/elevator.htm 919-707-7927 Report Number 9259-48-4998
State Number 24257

		EQUIPMENT INSPECTED			
State Number: 24257 Type of Unit: Pa		ssenger Floor to Floor: 1 to 4		oor: 1 to 4	
Capacity: 2500	Manuf: THYSSEN KRUPP Installed: 08/29/2006		Speed: 50		
Landings: 4			Rope Size: 0		
olts: 240 Complied:			Entrances: 1		
OWNER	Ī	00	OCCUPANT		
OCEANWALK HOA - C/O BEC MGMT. 1600 MORGANTOWN RD.			OCEAN WALK CONDOS #4		
			SE 58TH STREET		
PINEHURST, NC, 28374			OAK ISLAND, NC, 28465		
1 IIVEITORS1, IVC, 265/4		OA.			
	I	INSPECTION INFORMATION			
Inspection Date 09/16/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK	
		VIOLATIONS			
8.6.4.7.1 Clean the elevator pit.					
Items must be corrected by:	10/06/2009				
otify the Elevator Bureau in wromplainace with current codes.	iting on Corrected Violations Form	m when the following corrections	have been made in order to	bring your equipment into	
iolations pointed out to: UNA			Inspector		
	To make changes to the invoice mailing address please call: 919-733-0372				
THIS IS NOT AN INVOICE	OCEANWALK HOA - C/O BEC MGMT. An invoice will be mailed to: 1600 MORGANTOWN RD. PINEHURST, NC, 28374				