



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9265-48-1175
State Number
23253

EQUIPMENT INSPECTED

State Number: 23253	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 4500	Manuf: OTIS	Speed: 150
Landings: 3	Installed: 02/07/2006	Rope Size: .
Volts: 208	Complied:	Entrances: 1
OWNER	OCCUPANT	
SAIEED CONSTRUCTION	WATERFORD MEDICAL BLDG.	
1135 MILITARY CUTOFF	509 OLD WATERFORD WAY	
WILMINGTON, NC, 28405	LELAND, NC, 28451	

INSPECTION INFORMATION

Inspection Date 09/22/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.1.1.2	Put the in car emergency telephone in proper working order.
8.6.4.7.1	Clean the elevator pit.

Items must be corrected by: 10/12/2009

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: LISA BRITT

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SAIEED CONSTRUCTION
1135 MILITARY CUTOFF
WILMINGTON, NC, 28405