



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9266-48-5053
State Number
14064

EQUIPMENT INSPECTED

State Number: 14064	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: KONE	Speed: 80
Landings: 2	Installed: 08/15/1990	Rope Size:
Volts: 460	Complied: 09/07/1990	Entrances: 1
OWNER	OCCUPANT	
BRUNSWICK COMMUNITY COLLEGE	BRUNSWICK COMMUNITY COLLEGE	
PO BOX 30	2001 ENTERPRISE DRIVE	
SUPPLY, NC, 28462	LELAND, NC, 28451	

INSPECTION INFORMATION

Inspection Date 09/23/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: MANAGEMENT

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BRUNSWICK COMMUNITY COLLEGE
PO BOX 30
SUPPLY, NC, 28462