



INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9271-17-1065
State Number
23443

EQUIPMENT INSPECTED

State Number: 23443	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 95
Landings: 2	Installed: 12/07/2005	Rope Size:
Volts: 208	Complied: 01/05/2006	Entrances: 1
OWNER	OCCUPANT	
SPERRY VAN NESS	1985 HENDESONVILLE RD. LOT 4	
1100 RIDGEFIELD BLVD.	1985 HENDERSONVILLE RD	
ASHEVILLE, NC, 28806	ASHEVILLE, NC, 28803	

INSPECTION INFORMATION

Inspection Date 09/28/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

8.6.4	perform the annual no load test.
8.6.4	Clean the pit
8.6.4	Provide a monthly phase 1 and 2 test.
8.6.4	Perform the annual smoke detector test.

Items must be corrected by: 10/28/2009

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: office

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SPERRY VAN NESS
1100 RIDGEFIELD BLVD.
ASHEVILLE, NC, 28806