



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9272-12-161
State Number
6345

EQUIPMENT INSPECTED

State Number: 6345	Type of Unit: Freight	Floor to Floor: 1 to 2
Capacity: 3500	Manuf: SOUTHERN	Speed: 50
Landings: 2	Installed: 07/07/1969	Rope Size:
Volts: 220	Complied: 03/21/2000	Entrances: 1
OWNER	OCCUPANT	
JERRY T WARREN & ASSOC	JERRY T WARREN & ASSOC	
900 N MAIN STREET	900 N MAIN STREET	
RANDLEMAN, NC, 27317	RANDLEMAN, NC, 27317	

INSPECTION INFORMATION

Inspection Date 09/29/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 12 - Essick	County RANDOLPH
-------------------------------	----------------------------	---------------------------------	--------------------------	--------------------

76

VIOLATIONS

8.11 Perform annual test

Items must be corrected by: 10/29/2009

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jerry Warren

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

JERRY T WARREN & ASSOC
900 N MAIN STREET
RANDLEMAN, NC, 27317