



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9285-17-2473
State Number
4309

EQUIPMENT INSPECTED

State Number: 4309	Type of Unit: Passenger	Floor to Floor: B to 3
Capacity: 3000	Manuf: OTIS	Speed: 300
Landings: 4	Installed: 02/19/1960	Rope Size: 5/8
Volts: 240	Complied: 02/19/1960	Entrances: 1
OWNER	OCCUPANT	
ASHEVILLE BUNCOMBE TECH COLL	ASHEVILLE BUNCOMBE TECH COMM COLLEGE	
340 VICTORIA RD	1459 SANDHILL RD.	
ASHEVILLE, NC, 28801	CHANDLER, NC, 28715	

INSPECTION INFORMATION

Inspection Date 10/12/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

note no violations

Items must be corrected by: 10/12/2009

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Eddie

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHEVILLE BUNCOMBE TECH COLL
340 VICTORIA RD
ASHEVILLE, NC, 28801