N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9294-48-1750
State Number
16310

EQUIPMENT INSPECTED

State Number: **16310**
Capacity: 2100
Landings: 2
Volts: 208

Type of Unit: Passenger
Manuf: OTIS
Installed: 08/21/1996
Complied: 10/03/1996

Floor to Floor: 1 to 2
Speed: 100
Rope Size:
Entrances: 1

OWNER
OCEAN ISLE BEACH TOWN HALL
3 W THIRD ST
OCEAN ISLE, NC, 27469

OCCUPANT
OCEAN ISLE BEACH TOWN HALL
3 W THIRD ST
OCEAN ISLE, NC, 28469

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
10/21/2009	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

8.6.4.15 Emergency operation of signaling devices, lighting, communication, and ventilation, shall be maintained. EMER. PHONE INOPERATIVE.

Items must be corrected by: 11/10/2009

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: LARRY

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
OCEAN ISLE BEACH TOWN HALL
3 W THIRD ST
OCEAN ISLE, NC, 27469