



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9301-48-4390
State Number
23790

EQUIPMENT INSPECTED

State Number: 23790	Type of Unit: Passenger	Floor to Floor: 1 to 5
Capacity: 2500	Manuf: SCHINDLER	Speed: 125
Landings: 5	Installed: 04/26/2006	Rope Size: 0
Volts: 208	Complied:	Entrances: 1
OWNER	OCCUPANT	
INTRACOASTAL LIVING, LLC	THE PRESERVE BLDG #2 - CAR # 1	
1610 HWY 17 NORTH	2100 MARSH GROVE LANE	
MYRTLE BEACH, SC, 29588	OAK ISLAND, NC, 28465	

INSPECTION INFORMATION

Inspection Date 10/28/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: unavailable

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372
An invoice will be mailed to:
INTRACOASTAL LIVING, LLC
1610 HWY 17 NORTH
MYRTLE BEACH, SC, 29588