



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9302-24-5124
State Number
22572

EQUIPMENT INSPECTED

State Number: 22572	Type of Unit: Passenger	Floor to Floor: 1 to 9
Capacity: 2500	Manuf: OTIS	Speed: 200
Landings: 9	Installed: 04/26/2005	Rope Size: .
Volts: 208	Complied: 09/14/2005	Entrances: 1

OWNER

21 BATTERY PARK L.L.C.
C/O IPM CORP./ ATTN: TAMMY JONES
ARDEN, NC, 28704-0580

OCCUPANT

21 BATTERY PARK CONDOMINIUM
21 BATTERY PARK
ASHEVILLE, NC, 28801

INSPECTION INFORMATION

Inspection Date 10/29/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 24 - Moore	County BUNCOMBE	11 B
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

- 8.6.10.1 Update the monthly fire service log. Last date 6/09
- 2.14.7.4 Protect the car lights from accidental contact. Sleeve the tubes and endcaps or a solid ceiling.
- 8.6.1.2.1 Provide a written maintenance program. Locate a sign on the controller for location and reporting of defects.

Items must be corrected by: 11/28/2009

Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Mailed to IPM

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

21 BATTERY PARK L.L.C.
C/O IPM CORP./ ATTN: TAMMY JONES
ARDEN, NC, 28704-0580