N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
**9302-48-2355**
State Number
**22646**

## EQUIPMENT INSPECTED

State Number: **22646**
Capacity: 4500
Landings: 2
Volts: 208

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 04/27/2005
Complied: 04/27/2005

Floor to Floor: 1 to 2
Speed: 80
Rope Size:
Entrances: 1

OWNER
KEN CARLOUGH
1430 COMMONWEALTH DR. SUITE 102
WILMINGTON, NC, 28403

OCCUPANT
BRUNSWICK MEDICAL CAMPUS
346 OCEAN HIGHWAY WEST
SUPPLY, NC, 28462

## INSPECTION INFORMATION

| Inspection Date | Type Inspection | Certificate Status | Inspector | County | |
|---|---|---|---|---|---|
| 10/29/2009 | Routine | Re-issued | 48 - Martin | BRUNSWICK | 10 |

## VIOLATIONS

5.1.21.1 Put the in car alarm bell in working order.

Items must be corrected by: 11/08/2009

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: unavailable

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
KEN CARLOUGH
1430 COMMONWEALTH DR. SUITE 102
WILMINGTON, NC, 28403