



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**9306-48-1926**  
State Number  
**24615**

#### EQUIPMENT INSPECTED

State Number: <b>24615</b>	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: SCHINDLER	Speed: 125
Landings: 4	Installed: 09/24/2008	Rope Size:
Volts: 208	Complied: 09/24/2008	Entrances: 1
OWNER	OCCUPANT	
INTERCOASTAL LIVING LLC	THE PRESERVE BLDG #4 - CAR 1	
1610 HWY 17 N	3803-05 OLD BRIDGE ROAD	
N MYRTLE BEACH, SC, 29582	OAK ISLAND, NC, 28465	

#### INSPECTION INFORMATION

Inspection Date 11/02/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

#### VIOLATIONS

- 8.6.1.6.3[e] Properly maintain all Control and operating circuits and devices. REPAIR G FL. CALL BUTTON.
- 2.7.5.1 Put the machine room lights in working order.
- 8.11.1.6 Provide a metal with test date, the requirement number requiring the test, and the name of the person or firm performing the test inside the machine room for all Categories 3, 5 tests for electric elevators and 1,3, 5 tests for hydraulic elevators

Items must be corrected by: 11/22/2009

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILALBLE

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

INTERCOASTAL LIVING LLC  
1610 HWY 17 N  
N MYRTLE BEACH, SC, 29582