



INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9308-24-4959
State Number
9472

EQUIPMENT INSPECTED

State Number: **9472** Type of Unit: Passenger Floor to Floor: 1 to 3
Capacity: 2500 Manuf: ASHEVILLE Speed: 100
Landings: 3 Installed: 05/16/1980 Rope Size:
Volts: 208 Complied: 05/16/1980 Entrances: 1

OWNER OCCUPANT
ALCO PROPERTY MANAGEMENT ARROWHEAD APARTMENTS
35 UNION 100 CHEERIO LANE
MEMPHIS, TN, 38103 ASHEVILLE, NC, 28803

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
11/04/2009	Routine	Re-issued	24 - Moore	BUNCOMBE	11 B

VIOLATIONS

2.14.7.4 Protect the car lights from accidental contact. End cap missing on floresent tube inside cab.

Items must be corrected by: 12/04/2009

Elevator Name: FRONT ELEVATOR / # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Andrew Davis Herman Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALCO PROPERTY MANAGEMENT
35 UNION
MEMPHIS, TN, 38103