



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9308-48-2083
State Number
21706

EQUIPMENT INSPECTED

State Number: 21706	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: OTIS	Speed: 125
Landings: 2	Installed: 08/28/2003	Rope Size: 0
Volts: 208	Complied: 08/28/2003	Entrances: 1

OWNER

SOUTHERN SHORE VILLAS HOA
122 SE 58TH. ST
OAK ISLAND, NC, 28645

OCCUPANT

SOUTHERN SHORE VILLAGE
122 SE 58TH ST
OAK ISLAND, NC, 28645

INSPECTION INFORMATION

Inspection Date 11/04/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

- 8.6.4.8.2 Remove all materials from machine room (machinery space) not pertaining to the maintenance or operation of the elevator(s).
8.6.1.6.3[e] Properly maintain all Control and operating circuits and devices. REPAIR G LEVEL CALL BUTTON & 3RD. CALL BUTTON LIGHT.

Items must be corrected by: 11/24/2009

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JACK

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SOUTHERN SHORE VILLAS HOA
122 SE 58TH. ST
OAK ISLAND, NC, 28645