



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9309-4-2047
State Number
10465

EQUIPMENT INSPECTED

State Number: 10465	Type of Unit: Passenger	Floor to Floor: L to 11
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 350
Landings: 11	Installed: 10/07/1983	Rope Size: 1/2
Volts: 208	Complied: 10/04/2006	Entrances: 1

OWNER
SUGAR TOP HOMEOWNERS
303 SUGAR TOP DRIVE
BANNER ELK, NC, 28604

OCCUPANT
SUGAR TOP RESORT
303 SUGAR TOP DRIVE
BANNER ELK, NC, 28604

INSPECTION INFORMATION

Inspection Date 11/05/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 4 - Henegar	County AVERY
-------------------------------	----------------------------	---------------------------------	--------------------------	-----------------

6

VIOLATIONS

n/a No violations found

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Sugar Top Homeowners # 828-898-5226

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SUGAR TOP HOMEOWNERS
303 SUGAR TOP DRIVE
BANNER ELK, NC, 28604