



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**9313-16-2131**  
State Number  
**6858**

EQUIPMENT INSPECTED

State Number: <b>6858</b>	Type of Unit: Passenger	Floor to Floor: B to 2
Capacity: 2000	Manuf: WESTBROOK	Speed: 100
Landings: 3	Installed: 06/15/1972	Rope Size: 0
Volts: 220	Complied: 10/25/1993	Entrances: 1
OWNER	OCCUPANT	
BEAUFORT CO COURTHOUSE	BEAUFORT CO COURT HOUSE	
PO BOX 1027	112 W SECOND ST	
WASHINGTON, NC, 27889	WASHINGTON, NC, 27889	

INSPECTION INFORMATION

Inspection Date 11/09/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

8.6.4.8.1      Clean the elevator machine room. Oil in floor

Items must be corrected by: 12/09/2009

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Annette in Maintenance

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BEAUFORT CO COURTHOUSE  
PO BOX 1027  
WASHINGTON, NC, 27889