



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**9314-48-3988**  
State Number  
**21810**

EQUIPMENT INSPECTED

State Number: <b>21810</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: SCHINDLER	Speed: 100
Landings: 2	Installed: 07/23/2003	Rope Size: 0
Volts: 208	Complied: 07/30/2003	Entrances: 1
OWNER	OCCUPANT	
SOUTHPORT BAPTIST CHURCH	SOUTHPORT BAPTIST CHURCH	
200 N HOWE STREET	200 N HOWE STREET	
SOUTHPORT, NC, 28416	SOUTHPORT, NC, 28416	

INSPECTION INFORMATION

Inspection Date 11/10/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: GALE

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SOUTHPORT BAPTIST CHURCH  
200 N HOWE STREET  
SOUTHPORT, NC, 28416