



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9323-16-5272
State Number
2972

EQUIPMENT INSPECTED

State Number: 2972	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 4000	Manuf: OTIS	Speed: 200
Landings: 4	Installed: 10/18/1957	Rope Size: 5/8
Volts: 208	Complied: 10/18/1957	Entrances: 2

OWNER
BEAUFORT COUNTY HOSPITAL
628 E 12TH ST
WASHINGTON, NC, 27889

OCCUPANT
BEAUFORT COUNTY HOSPITAL
628 E 12TH ST
WASHINGTON, NC, 27889

INSPECTION INFORMATION

Inspection Date 11/19/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

8.11.2.2.2	Perform an annual no load safety test and provide proper tags.
8.11.2.1.3	Replace Hoisting Ropes

Items must be corrected by: 12/19/2009

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Mike in Maintenance

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BEAUFORT COUNTY HOSPITAL
628 E 12TH ST
WASHINGTON, NC, 27889