



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9323-36-3455
State Number
H1137

EQUIPMENT INSPECTED

State Number: H1137	Type of Unit: Hand Lift	Floor to Floor: LL to UL
Capacity: 750	Manuf: GARAVENTA	Speed: 10
Landings: 2	Installed: 05/29/2001	Rope Size:
Volts: 220	Complied: 05/29/2001	Entrances: 2
OWNER	OCCUPANT	
ALAMANCE BURLINGTON SCHOOLS	WILLIAMS HIGH SCHOOL	
1712 VAUGHN RD	1307 S CHURCH ST	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 11/19/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

A18 Properly maintain hoist way door unlocking devices. Top door will shut lift down in operation

Items must be corrected by: 12/19/2009

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: office

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAMANCE BURLINGTON SCHOOLS
1712 VAUGHN RD
BURLINGTON, NC, 27215