



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9327-36-5146
State Number
6040

EQUIPMENT INSPECTED

State Number: 6040	Type of Unit: Passenger	Floor to Floor: G to 3
Capacity: 2500	Manuf: SOUTHERN	Speed: 100
Landings: 4	Installed: 09/06/1968	Rope Size:
Volts: 480	Complied: 06/12/1987	Entrances: 1
OWNER	OCCUPANT	
FIRST BAPTIST CHURCH	FIRST BAPTIST CHURCH	
PO BOX 2686	400 S BROAD ST	
BURLINGTON, NC, 27216-2686	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 11/23/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: office

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

FIRST BAPTIST CHURCH
PO BOX 2686
BURLINGTON, NC, 27216-2686