



INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
www.nclabor.com/elevator.htm  
919-707-7927

Report Number  
**9335-45-1295**  
State Number  
**10065**

EQUIPMENT INSPECTED

State Number: **10065**                      Type of Unit: Passenger                      Floor to Floor: M to 14  
Capacity: 3500                              Manuf: WESTINGHOUSE                      Speed: 450  
Landings: 13                                Installed: 03/05/1982                      Rope Size: 5/8  
Volts: 480                                    Complied: 04/29/1982                      Entrances: 1

OWNER  
HINES CHARLOTTE PLAZA LP  
201 S COLLEGE ST SUITE 2270  
CHARLOTTE, NC, 28244

OCCUPANT  
CHARLOTTE PLAZA  
201 S. COLLEGE ST.  
CHARLOTTE, NC, 28244

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
12/01/2009	Routine	Re-issued	45 - Hardin	MECKLENBURG	60 C

VIOLATIONS

- 2.12.2.4.1      Take steps to seal holes in hoistway around the hall button boxes.
- 8.6.3.3.3      Provide proper distance between counterweight and buffer. Shorten cables.
- 2.2.3            Provide duct cover on riser.
- 8.6              Provide end cap on riser and secure wiring hanging in hoistway.

Items must be corrected by: 12/31/2009

Elevator Name: ELEVATOR #2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jesse Amundson, 704-376-4186

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372  
An invoice will be mailed to: HINES CHARLOTTE PLAZA LP  
201 S COLLEGE ST SUITE 2270  
CHARLOTTE, NC, 28244