



INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
www.nclabor.com/elevator.htm  
919-707-7927

Report Number <b>9337-48-5328</b> State Number <b>11693</b>
--

EQUIPMENT INSPECTED

State Number: <b>11693</b>	Type of Unit: Passenger	Floor to Floor: G to 3
Capacity: 2000	Manuf: KONE	Speed: 125
Landings: 4	Installed: 02/19/1987	Rope Size: .
Volts: 0	Complied: 02/19/1987	Entrances: 4

OWNER	OCCUPANT
WEST BEACH VILLA	WEST BEACH VILLA
2714 W BEACH DRIVE	2714 W. BEACH DRIVE
LONG BEACH, NC, 28461	LONG BEACH, NC, 28461

INSPECTION INFORMATION

Inspection Date 12/03/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.13.1[k] Properly maintain door closers, where required. REPAIR MOTOR ROOM DOOR TO CLOSE AND LOCK ON ITS OWN.

Items must be corrected by: 12/23/2009

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

WEST BEACH VILLA  
2714 W BEACH DRIVE  
LONG BEACH, NC, 28461