



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9338-36-5027
State Number
14910

EQUIPMENT INSPECTED

State Number: 14910	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 4	Installed: 04/18/1994	Rope Size:
Volts: 480	Complied: 04/18/1994	Entrances: 2
OWNER	OCCUPANT	
ELON UNIVERSITY	ELON UNIV / ATHLETIC CENTER	
PO BOX 2950	104 E HAGGARD	
ELON, NC, 27244	ELON, NC, 27244	

INSPECTION INFORMATION

Inspection Date 12/04/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

8.6.4.8.2 Remove all materials from machine room (machinery space) not pertaining to the maintenance or operation of the elevator(s).

Items must be corrected by: 01/03/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: bob

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELON UNIVERSITY
PO BOX 2950
ELON, NC, 27244