



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9349-48-5978
State Number
12252

EQUIPMENT INSPECTED

State Number: 12252	Type of Unit: Passenger	Floor to Floor: 1 to -
Capacity: 4000	Manuf: SOUTHERN	Speed: 100
Landings: 5	Installed: 11/03/1987	Rope Size: 5/8
Volts: 480	Complied: 06/12/2006	Entrances: 1
OWNER	OCCUPANT	
EPCOR USA	EPCOR USA	
PO BOX 10836	1281 POWERHOUSE DR.	
SOUTHPORT, NC, 28461	SOUTHPORT, NC, 28461	

INSPECTION INFORMATION

Inspection Date 12/15/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.26.1.4.1	Put the car top inspection station in proper working order.
2.2.5.1	Put the pit lights in proper working order.

Items must be corrected by: 01/14/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: MARK WILSON

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

EPCOR USA
PO BOX 10836
SOUTHPORT, NC, 28461