N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9362-36-4553
State Number
24719

EQUIPMENT INSPECTED

State Number: **24719**
Capacity: 2500
Landings: 4
Volts: 480

Type of Unit: Passenger
Manuf: TKE
Installed: 09/22/2008
Complied: 09/22/2008

Floor to Floor: 1 to 4
Speed: 350
Rope Size: 3/4
Entrances: 4

OWNER
LABCORP
531 S SPRING STREET
BURLINGTON, NC, 27215

OCCUPANT
LABCORP HEADQUARTERS
531 S SPRING STREET
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
12/28/2009	Routine	Re-issued	36 - Kirkman	ALAMANCE

1

VIOLATIONS

No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: office

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
LABCORP
531 S SPRING STREET
BURLINGTON, NC, 27215