



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9363-36-1957
State Number
12664

EQUIPMENT INSPECTED

State Number: 12664	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 05/31/1988	Rope Size:
Volts: 200	Complied: 06/03/1988	Entrances: 1
OWNER	OCCUPANT	
HAWKS & LOVE	B B & T	
PO BOX 1796	2040 S CHURCH ST	
BURLINGTON, NC, 27216	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 12/29/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: office

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

HAWKS & LOVE
PO BOX 1796
BURLINGTON, NC, 27216