N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9364-36-4077
State Number
19932

EQUIPMENT INSPECTED

State Number: **19932**
Capacity: 2500
Landings: 2
Volts: 208

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 06/26/2001
Complied: 06/26/2001

Floor to Floor: 1 to 2
Speed: 95
Rope Size:
Entrances: 1

OWNER
PARKER OFFICE BLDG
3102 S CHURCH ST
BURLINGTON, NC, 27216

OCCUPANT
STATE FARM INS
3102 S CHURCH ST
BURLINGTON, NC, 27216

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
12/30/2009	Routine	Re-issued	36 - Kirkman	ALAMANCE

1

VIOLATIONS

No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: office

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
PARKER OFFICE BLDG
3102 S CHURCH ST
BURLINGTON, NC, 27216